



**Underwriters
Laboratories Inc.**

File E161171

Vol 1

Issued: 1996-02-23

Revised: 2007-03-15

FOLLOW-UP SERVICE PROCEDURE
(TYPE R)

COMPONENT - SWITCHES, INDUSTRIAL CONTROL
(NRNT2, NRNT8)

Manufacturer: UNION ELECOM CO LTD
(100098-662) 102-1207 CHUNUI TECHNO PARK 1
200-1 CHUNUI-DONG
WONMI-KU
BUCHUN-SI 420-857 KOREA

Applicant: UNION ELECOM CO LTD
(196750-001) 34-2 SAMJUNG-DONG
OJUNG-KU
BUCHUN-SI KYONGGI-DO KOREA

Recognized Company: SAME AS APPLICANT
(196750-001)

This Procedure authorizes the above manufacturer to use the marking specified by Underwriters Laboratories Inc. (UL), or any authorized licensee of UL, only on products covered by this Procedure, in accordance with the applicable UL Services Agreement.

The prescribed Mark or Marking shall be used only at the above manufacturing location on such products which comply with this Procedure and any other applicable requirements.

The Procedure contains information for the use of the above named Manufacturer and representatives of Underwriters Laboratories Inc. and is not to be used for any other purpose. It is lent to the Manufacturer with the understanding that it is not to be copied, either wholly or in part, and that it will be returned to Underwriters Laboratories Inc. or any authorized licensee of UL, upon request.

This PROCEDURE, and any subsequent revision, is the property of Underwriters Laboratories Inc. (UL) and the authorized licensee of UL and is not transferable.

Underwriters Laboratories Inc.

Stephen Hewson
Senior Vice President
Global Follow-Up Service Operations

William R. Carney
Director
North American Certification Program



and Report

RATINGS:

Model	Contact	Input	Output	
		Rated Voltage	Rated Voltage (Vac)	Max. Load Current (A) (#)
PDA1-201Z	1	4 - 32 Vdc	50 - 240	2
PDA1-202R	1	4 - 32 Vdc	50 - 240	2
PDA1-203E	1	4 - 32 Vdc	50 - 240	3
PDA1-203R	1	4 - 32 Vdc	50 - 240	3
SDA2-215Z	2	4 - 32 Vdc	50 - 240	15
SDA2-225Z	2	4 - 32 Vdc	50 - 240	25
SDA2-240Z	2	4 - 32 Vdc	50 - 240	40
SDA2-250ZU	2	4 - 32 Vdc	50 - 240	45
SDA2-415Z	2	4 - 32 Vdc	50 - 460	15
SDA2-425Z	2	4 - 32 Vdc	50 - 460	25
SDA2-440Z	2	4 - 32 Vdc	50 - 460	40
SDA2-450ZU	2	4 - 32 Vdc	50 - 460	45
SAA2-215Z	2	85 - 240 Vac	50 - 240	15
SAA2-225Z	2	85 - 240 Vac	50 - 240	25
SAA2-240Z	2	85 - 240 Vac	50 - 240	40
SAA2-250ZU	2	85 - 240 Vac	50 - 240	45
SAA2-415Z	2	85 - 240 Vac	50 - 460	15
SAA2-425Z	2	85 - 240 Vac	50 - 460	25
SAA2-440Z	2	85 - 240 Vac	50 - 460	40
SAA2-450ZU	2	85 - 240 Vac	50 - 460	45
SDA3-215Z	3	4 - 32 Vdc	50 - 240	15
SDA3-225Z	3	4 - 32 Vdc	50 - 240	25
SDA3-240Z	3	4 - 32 Vdc	50 - 240	40
SDA3-250ZU	3	4 - 32 Vdc	50 - 240	45
SDA3-415Z	3	4 - 32 Vdc	50 - 460	15
SDA3-425Z	3	4 - 32 Vdc	50 - 460	25
SDA3-440Z	3	4 - 32 Vdc	50 - 460	40
SDA3-450ZU	3	4 - 32 Vdc	50 - 460	45
SAA3-215Z	3	85 - 240 Vac	50 - 240	15
SAA3-225Z	3	85 - 240 Vac	50 - 240	25
SAA3-240Z	3	85 - 240 Vac	50 - 240	40
SAA3-250ZU	3	85 - 240 Vac	50 - 240	45
SAA3-415Z	3	85 - 240 Vac	50 - 460	15
SAA3-425Z	3	85 - 240 Vac	50 - 460	25
SAA3-440Z	3	85 - 240 Vac	50 - 460	40
SAA3-450ZU	3	85 - 240 Vac	50 - 460	45

- See the Table I add Table II for referenced load current in details.